



GENERAL NOTES:

1. Upon completion and acceptance of bacterial testing, the corp stop shall be shut off. The copper riser shall be disconnected and removed. The corp stop shall remain closed in place.

DETAIL NO. 2399	City of Scottsdale Standard Details	APPROVED BY: Scottsdale Standards & Specifications Committee	TEMPORARY TAP FOR CHLORINE INJECTION	DETAIL NO. 2399
---------------------------	------------------------------------------------	--------------------------------------------------------------------------------	---------------------------------------------	---------------------------