

Fire Alarms/ Sprinkler Systems

The following offers the best early warning and quickest response to a fire:

- A fully functional fire sprinkler system connected to a central station monitoring (tested annually by a licensed firm).
- A fire detection and notification system connected to a central station monitoring (tested annually by a licensed firm).
- Portable fire extinguishers that are wall mounted near exits, highly visible, unobstructed and located no more than 75' from anywhere in the building (service annually by a licensed firm).
- A hood and duct fire system over commercial cooking appliances (tested semi-annually by a licensed firm).

ON THE OUTSIDE:

- Clearly marked and visible fire lanes.
- Knox box and Knox lock system.
- Clearly labeled fire alarm, fire riser and utility rooms.
- Clear and visible street numbers and suite numbers.
- Clearly labeled fire department connections.



Are You Up to Code?

Scottsdale Fire Department
Prevention Services

Contact Us



480-312-8000 (Main Fire)
480-312-1855 (Prevention)



8401 E. Indian School Rd
Scottsdale, AZ 85251



Fire@ScottsdaleAZ.com
www.ScottsdaleFD.com



Annual Inspections

Why?

It is the law. State and local fire code requires that every business receive a fire inspection regularly. These inspections will greatly reduce the occurrence of injury and fire in your business.

What You Can Do?

The best way for you to prepare for your upcoming inspection is to follow the preventative measures outlined in this brochure.

How We Can Help?

Businesses requiring an annual or target inspection should call 480-312-1855 or email SFDinspection@scottsdaleaz.gov

What to Expect:


A uniformed Scottsdale Deputy Fire Marshal, Fire Inspector or Firefighter will:

- Visit your facility during normal business hours.
- Always be courteous and considerate of your time.
- Comply with the best time to conduct the required inspection.
- Always clearly state inspection results in writing with a re-inspection date assigned, if required.
- Information may be left to enable you to self-inspect your premise in order to be ready for the official inspection.
- A time extension may be granted by the Fire Marshal upon written request providing a reasonable explanation.

Understanding the Results

- The Inspector is there to help you and will be glad to explain the results and answer any questions you may have.
- At any time, you may contact us at the Fire Prevention Services Division by calling 480-312-1855.

Evacuation Plan



BE PREPARED

- Post your building's evacuation plan
- Know at least two ways out of your work area/building
- Conduct regular fire drills
- Know where the fire extinguishers are located and how to use them stairs to exit; DO NOT use the elevator
- Avoid blocking exits
- Keep hallways, stairways, and exits clear of trash, cleaning supplies, and other storage
- Report locked or blocked exit doors to building owner and the fire department

Scottsdale Fire Department is confident that through education and awareness, your place of business can be a fire safe facility.

